



1 GROUND FLOOR PIPING PLAN  
1/8" = 1'-0"

#### GENERAL NOTES:

- A. UNLESS NOTED OTHERWISE, ALL BRANCH HWS AND HWR PIPING TO VAV BOXES SHALL BE 3/4 INCH.

#### KEY NOTES:

- 1 PROVIDE THREE-WAY CONTROL VALVE.  
2 MOUNT ASSOCIATED CONTROL AND BALANCING VALVES ABOVE LAY-IN CEILING.

100% OWNER REVIEW  
NOT FOR CONSTRUCTION  
12/16/2011



**RSP Architects**  
1220 Marshall Street NE  
Minneapolis  
Minnesota 55413-1036  
612.677.7100  
612.677.7499 fax  
www.rsparch.com

NOTICE: The designs shown and described herein including all technical drawings, graphics, and models thereof, are proprietary and cannot be copied, duplicated or commercially exploited, in whole or in part, without express written permission of RSP Architects. These are available for limited review and evaluation by clients, consultants, contractors, government agencies, vendors and office personnel only in accordance with this Notice.

© Copyright RSP Architects 2011. All rights reserved.



#### CONSULTANTS:

**Structural**  
Van Sickle, Allen & Assoc.  
2955 Xenium Lane N  
Suite 10  
Plymouth, MN 55441

**EVS**  
10250 Valley View Road  
Suite 113  
Eden Prairie, MN 55344

**Landscape**  
Damon Farber Assoc.  
923 Nicollet Mall  
Minneapolis, MN 55402

**Fire Protection**  
Gary Trivinski Associates  
Engineering  
94 Boston Hill  
Larksville, PA 18851-3298



**DUNHAM**  
Dunham Associates, Inc.  
60 South Park Street / Suite 1000  
Minneapolis, Minnesota 55402-1000  
phone 612.444.7000  
fax 612.444.7001  
www.dunhaminc.com  
mechanical & electrical  
consulting engineering  
TOWNSHIP/PA/STATE

I hereby certify that this plan, specification or report was prepared by me or under my direct supervision and that I am a duly licensed Engineer under the laws of the State of Minnesota.

Signature

Registration No.

Date 11/17/2011

APPROVED: SERVICE LINE DIRECTOR	DATE	APPROVED: INJECTION CONTROL NURSE	DATE
APPROVED: GEMS COORDINATOR	DATE	APPROVED: PATIENT SAFETY	DATE
APPROVED: PROJECTS SECTION MANAGER	DATE	APPROVED: CHIEF OF POLICE	DATE
APPROVED: DIRECTOR FWS	DATE	APPROVED: SAFETY MANAGER	DATE

GROUND FLOOR PIPING PLAN	DATE	APPROVED: CHIEF OF STAFF	DATE
APPROVED: MEDICAL CENTER DIRECTOR	DATE	APPROVED: CHIEF OF POLICE	DATE

PROJECT TITLE LONG TERM / INTERMEDIATE PSYCHIATRIC UNIT	BUILDING No	CHECKED BY	ISSUED BY
4801 VETERANS DR. SAINT CLOUD, MN	DM	BB	BB

12/16/2011	12/16/2011
AS NOTED	AS NOTED
2012.01.00	2012.01.00
M102	M102

